

360

N Sepulveda Blvd

AQI
74

320

N Sepulveda Blvd

AQI
74

300

N Sepulveda Blvd


AQI
74

Designo CC Building Management System

Building Health

Building Address Line 01
City, State, Zip

Siemens Contact: 800-806-0886





Air Quality Index (AQI) refers to the EPA's index for reporting air quality, on a scale from 0 - 500. This index keeps in mind all of the major pollutants, pathogens, and risks in the air that directly effect health.

EXCELLENT

COVID-19 survival is low and airborne transmissions is unlikely.

GOOD

COVID-19 survival is moderate and airborne transmission is possible, but poses little to no health risk.

FAIR

COVID-19 survival is prolonged and airborne transmission is.

BAD

COVID-19 survival is high and airborne transmissions is likely.

SEVERE

COVID-19 survival is severely high and airborne transmissions is certain.

PM 0.1-2.5 (ug/m3)

0 - 12

12.1 - 35.4

35.5 - 55.4

55.5 - 150.4

150.5+

TVOCs (ppb)

0 - 220

221 - 660

661 - 1540

1541 - 2200

2201+

CO2 (ppm)

0 - 1000

1001 - 1500

1501 - 2000

2001 - 2500

2501+

AQI

0 - 50

51 - 100

101 - 150


151 - 200

201 - 500



4TH FLOOR AIR QUALITY INDEX

1	AQI	72.69 ppm
2	CO2	72.69 ppm
3	TEMPERATURE	17.84 °F
4	HUMIDITY	10.8 %
5	TVOC	13.41 ppb
6	PM 10	72.69 ug/m3
7	PM 2.5	17.84 ug/m3
8	PM0.1	72.69 ug/m3
9	PM0.3	64.88 ug/m3
10	PM0.5	13.41 ug/m3
11	PM1.0	72.69 ug/m3
12	PM5.0	10.77 ug/m3



Key Range AQI Data Description

EXCELLENT

GOOD

FAIR

BAD

SEVERE



DEVICE	CURRENT VALUE
AQI	86.53
CO2	60.10 ppm
TVOC	86.53 ppb
HUMIDITY	60.10 %
TEMPERATURE	86.53 °F
PM0.1	86.53 ug/m3
PM0.3	60.10 ug/m3
PM0.5	86.53 ug/m3
PM1.0	60.10 ug/m3

DEVICE	CURRENT VALUE
PM5.0	86.53 ug/m3
OZONE	60.10 ppb/ppm
PC0.1	86.53 counts
PC0.3	60.10 counts
PC0.5	86.53 counts
PC1.0	86.53 counts
PC2.5	60.10 counts
PC5.0	86.53 counts
PC10.0	60.10 counts